

SEQ Water Supply and Sewerage Design & Construction Code

SEQ Accepted Infrastructure Products and Materials

SCHEDULE OF AMENDMENTS

Amendment No.6 – September 2016



This document contains information which is proprietary to the SEQ service providers and may not be used for purposes other than those intended without written consent from the SEQ service providers

Schedule of Amendments to SEQ Accepted IPAM Lists (Changes from June 2016 Version to September 2016 Version)

SEQ Accepted Civil IPAM List	
Products	Change
Category: Sewerage Pipes and Fittings- Non Pressure	
GRP Pipe and Fittings - Jacking Pipe	Added new product "Empire Infrastructure BOSSPIPE CC GRP" with "subject to acceptance" stipulation by all SPs.
Category: Sewerage Pipes and Fittings - Pressure	
DI Pipe	Added new products "Vinidex LINX and ZAP". PN20 not accepted by QUU and Unitywater with other classes being "subject to acceptance". All classes of LINX and ZAP are "subject to acceptance" by Logan and Redland. PE sleeving requirement relocated from Column F to Column B as item 4.7
PE Pipe Installed by Directional Drilling	Category removed from IPAM list. Replaced with Specified Requirement in column F against PE Pipe with: "For directional drilling installations, minimum SDR 9 (PN20) unless specified otherwise and install with SS316 tracer wire. Pipe wall thickness to be designed for installation forces."
PE Fittings	Additional information against product Vinidex "FRIALEN" Electrofusion Fittings.
Resilient Seated Gate Valves, Thermal Bonded Polymeric Coating	Added new product "DAEMCO" flanged resilient seated gate valves – WSAA PA 1517 (10/05/16). Accepted by Logan City Council, "subject to acceptance" stipulation by other SPs.
Category: Sewerage Miscellaneous Items	
Maintenance shaft covers, frames and risers DN<=450	Column H (LCC comments) – removal of stipulation "Use is subject to acceptance by SP" against Smartstream..
Maintenance Shaft PVC	Added Unitywater's requirement "DN225 risers not accepted. Min DN300 risers are accepted" under Column K.
Maintenance Shafts PE	Added Unitywater's requirement "DN225 risers not accepted. Min DN300 risers are accepted" under Column K.
Maintenance Shafts Polypropylene – DN225 and DN300 Risers	SMS and REHAU products approved by Redland. Column H (Redland comments) adjusted to "Approved for DN150 RIGSS only. Refer to clause 6.7.2 of the SEQ Sewerage Code". Added Unitywater's requirement "DN225 risers not accepted. Min DN300 risers are accepted" under Column K.
Category: Water Supply Pipes – Pressure	
DICL Pipe	Added new product "Vinidex LINX and ZAP". PN20 not accepted by QUU. Other classes have "subject to acceptance" stipulation by SPs except for Unitywater, which is "subject to acceptance" for PN20 only.
Small DN Ductile Iron Water Main pipe at PE OD's	New Product Category added with one new product "Bluetop" provided by Saint-Gobain PAM. Specified with Restrained Joints PN16. Use is "subject to acceptance" by all SPs.

This document contains information which is proprietary to the SEQ service providers and may not be used for purposes other than those intended without written consent from the SEQ service providers

PE Pipe	Column F Specified Requirements, added "For directional drilling installations, minimum SDR 9 (PN20) unless specified otherwise and install SS316 tracer wire".
Category: Water Supply Fittings – Pressure	
Small DN Ductile Iron Pipe Restraint Fittings at PE ODs	New Product Category added with one new product "Ezifit" provided by Saint-Gobain PAM. Specified for use directly with PE and Blutop pipe. "Subject to Acceptance" by all SPs.
Resilient Seated Gate Valves, thermal bonded polymeric coating.	Column B Specific Requirements Item 4.3 adjusted to: "Integral By-pass on DN450 and larger (Unitywater accepts either integral or constructed by-pass as per job specification)".
Resilient Seated Gate Valves, thermal bonded polymeric coating.	Added new product "DAEMCO" flanged resilient seated gate valves – WSAA PA 1517 (10/05/16). Accepted by Logan City Council, "subject to acceptance" by other SPs.
Butterfly Valves	Added new product "AVFI" valves. Accepted by City of Gold Coast and Unitywater, "subject to acceptance" by other SPs.
Category: Water Services	
Meter Boxes	Everhard Industries 368L*271W*316D (for 20 mm meters only) not accepted by QUU.
Category: Water Supply Miscellaneous Items	
Category: Emergency Storage Chambers	

SEQ Accepted Electrical IPAM List	
Product Type	Change

SEQ Accepted Mechanical IPAM List	
Products	Change
PUMPS	
ACTUATOR/ SOLENOID VALVES	
MISCELLANEOUS ITEMS	