

HARBOR VILLAGE RV PARK

Response to Granada Community Services District
January 4th, 2018 plan comment letter

Estimate of daily waste water generation be discharged.

Low (December)	165 gallons per day
Average (January-May, October and November)	374 gallons per day
Maximum (June-September)	957 gallons per day

Refer to the sewer plan for information on the proposed connection's to GCSDs wastewater facilities.

There will be no sewage dump station. All RV sites will have there own gravity fed sewer connection.

The maximum length of stay will be 28 days.

Monthly occupancy estimate

Low (December)	775 people per month 403 vehicles per month
Average (January-May, October and November)	1,380 people per month 780 vehicles per month
Maximum (June-September)	2,852 people per month 1,333 vehicles per month

None of the waste water infrastructure will occur on, cross, or be sited adjacent to a stream, riparian area, wetland, environmentally sensitive habitat area, trail open space, or scenic or view corridor.

Refer to the drainage plan for site runoff being directed to approved locations.

RECEIVED

MAR 1 2 2018

San Mateo County
Planning and Building Department

PLN2017-00320